



CONC. CRADLE NOTE:

USE CONC. CRADLES WHERE LESS THAN 18" VERTICAL SEPERATION IS PROVIDED BETWEEN THE OUTSIDE WALLS OF THE WATER OR SANITARY SEWER/LATERAL AND ANY PIPE CROSSING ABOVE.

TOWNSHIP OF FLORENCE  
WATER & SEWER DEPARTMENT

CONCRETE CRADLE  
DETAIL

DATE : 6/06  
DWN BY :

BY	DATE	REVISIONS